

Response to Questions  
CML 19-010  
Main Library Restroom Remodel

1. What is the required thickness of the SS-1 wall panels at the hand dryers?

1/2" thick solid surface (SS-1) panels.