

CML #18-011 Main Lighting Controls Improvements and Fixture Upgrades
Question and Request Clarifications Part 2

1. There are 2 EL1.12C Phase 3 drawings listed. One has 28 coded notes and one has 48 coded notes. Since there are no change dates listed on the drawings which one takes precedence?

A. Revision 60 is Phase II. Revision 61 is Phase III. Pricing is to be provided for the applicable scope of work for each phase.

2. On sheet EL1.10B in room B064 there are type A and R1 fixtures shown. Since this is marked as Rev61 are they part of the changes and if so then there is no listing for these fixture types. Are we to revise everything within the cloud or only the items with specific coded notes?

A. Type A and R1 are existing fixtures to remain. Only the items with specific coded notes are to be changed.

3. Since there are no specifications for this project will you accept type "MC" cable for branch wiring or do you want conduit & wire?

A. MC cable is acceptable, as long as it meets code requirements.

4. I have found Alternate 2 on drawing EL1.12C but, as yet, have not found Alternate #1. Could you please give guidance as to where alternate #1 is on the drawings.

A. Alternate #1 was deleted.