

Questions and Responses 11.16.18

1. Are all fan coil units accessible by ladder or do some require a lift?

At MLK, the Daikin lobby units will require a scissor lift to access.

At Hilliard CML has a large A frame ladder that the contractor can use to access any above ceiling unit.

Offeror should incorporate lift cost in the cost sheet.