

MEMORANDUM

To: All Interested Vendors

From: Dan Jones
Procurement Buyer

Date: April 4, 2021

Subject: Addendum No. 2
HVAC Replacement - Hilliard Branch
Modification of the SOW

Part I. Modification of the SOW

CML is adding a seventh unit to be replaced as part of this Project. To reflect this change, the following modifications are made to the Scope of Work for the ITB.

The table below shall replace the table on Page 12:

| TMA Tag # | Description | New unit | Floor/room |
|------------------|--|-------------------------------|-----------------------|
| HILI-HPU-012 | HEAT PUMP HOMEWORK HELP | TCV072 REAR | 2nd, 223 |
| HILI-HPU-029 | HEAT PUMP 2 ND FLR READING LOUNGE | TCV96 REAR | 2 ND , 237 |
| HILI-HPU-022 | HEAT PUMP 2ND FLR MAG AREA SOUTHEAST | TCV120 REAR | 2nd, 218 |
| HILI-HPU-028 | HEAT PUMP 2ND FLR READING ROOM MIDDLE | TCV160 REAR | 2nd, 237 |
| HILI-HPU-030 | HEAT PUMP 2ND FLR STACKS | TCV160 REAR | 2nd, 228 |
| HILI-HPU-023 | HEAT PUMP 2ND FLR HILLIARD RM | TCV036 left side return | 2nd, 223 |
| HILI-HPU-019 | HEAT PUMP 2ND FLR SEATING BY STAIRS | TCV192 REAR | 2nd, 218 |

The following information shall be added to the description of the Work on pps. 12-13:

One (1) TCV096 8 ton vertical water source heat pumps complete with belt drive motors, CXM control boards, single stage compressor, copper coils, "Ultra-quiet" sound attenuation and 2" filter frame. (Order #460/60/G)

ADD: 1¼"x24" stainless steel hose kit with shut-off valves, P/T ports, strainer with blowdown and automatic flow control valve.

**BIDDERS ARE REQUIRED TO ACKNOWLEDGE THE RECEIPT OF THIS MEMORANDUM
(ADDENDUM NO. 1) ON THE ACKNOWLEDGEMENT OF ADDENDA FORM IN THE ITB
DOCUMENTS**